



Practical Completion Certificate

Issued by: Morgan and Horowskyj Architects
address: The School Room, Castle Street, Abergavenny, Monmouthshire, NP7 5EE

Employer: The Rec. Benefice of the G.H.C. PCC
address: The Parish Office, St. Illtyd's Church, College Street, Llantwit Major

Contractor: Yardley Electrical Services Ltd
address: Oak Lodge, Woodside Hamlet, Ham Manor Park, Llantwit Major

Works: Lighting replacement/improvements
situated at: St. Giles Church, Gileston, Vale of Glamorgan

Job reference: 2124 (ELEC)

Certificate no: 01

Issue date: 14.03.2024



Contract dated: March 2024

Under the terms of the above-mentioned Contract,

I/we hereby certify that in my/our opinion

practical completion of the Works has been achieved

*Delete if not applicable

~~* and the Contractor has supplied the specified documents and drawings relating to the Contractor's Designed Portion~~

~~* and the Contractor has complied with the contractual requirements in respect of information for the health and safety file~~

on WEDNESDAY 13TH MARCH

20 24

To be signed by or for the issuer named above

Signed

Morgan & Horowskyj Architects

Distribution

Employer

Structural Engineer

CDM Co-ordinator

Contractor

M&E Consultant

Quantity Surveyor

Clerk of Works

File



eNotification

The Certificate of Compliance for your installation work has arrived. Please take time to read the document and the notes overleaf.

The Registered Installer named below has certified that the installation work detailed is compliant with Regulations 4 & 7 of The Building Regulations 2010 for England and Wales or; where applicable, based on the address of the installation, the Registered Installer has certified the work detailed is compliant with the requirements of bye-laws 5 & 7 of the Building Bye-Laws (Jersey), or Regulation 9 of the Isle of Man Building Regulations 2014.

Building Regulations Certificate of Compliance

Certificate Number
29857293

Date Completed
13/03/2024

Installer Name
Yardley Electrical Services
Registered no. 025998000

Address of Installation
c/o St Giles Church, Gileston
Barry, CF624HX

Description of Location
Dwelling

Description of Notifiable Work
Electrical (Wales)
E11 - Install electrical lighting and/or power outdoors



This certificate is issued by NICEIC, a trading brand of Certsure LLP, as agent for and on behalf of the NICEIC registered installer named above. This certificate is evidence, but not conclusive evidence, that the requirements specified in the certificate have been complied with. NICEIC does not accept any responsibility for the content of this certificate or for the quality of work detailed, except under the NICEIC Platinum Promise described overleaf.

This certificate is a valuable document. Please retain it in a safe place. If this is not an original certificate or if there is any doubt to its authenticity, visit www.checkmynotification.com

NOTES FOR RECIPIENTS

FOR WORK IN ENGLAND & WALES - This Building Regulations Certificate of Compliance is the NICEIC registered installer's confirmation that the certified work identified overleaf complies with Regulations 4 and 7 of The Building Regulations 2010. Details of the certified work have been notified to your local authority.

FOR WORK IN JERSEY - The installation work outlined overleaf has been undertaken by a person/enterprise registered with the States of Jersey-approved NICEIC Jersey Scheme. The certificate is the person/enterprise's confirmation their work complies with the Building Regulations and details of that work have been notified to the States of Jersey Building Control Department.

FOR WORK IN ISLE OF MAN - This Building Regulations Certificate of Compliance is the NICEIC registered installer's confirmation that the certified work identified overleaf complies with Regulation 9 of The Isle of Man Building Regulations 2014. Details of the certified work have been notified to your local authority.

Please check the details on this certificate are correct, ensuring the description of work undertaken, completion dates are both correct and the installer's name is that of the business that actually undertook the certified work. If you have any concerns regarding the work-type, date or the installer's name, please contact our Building Compliance team on 0333 015 6625.

Additional or replacement copies of Building Regulations Certificates of Compliance can be purchased from www.checkmynotification.com

OUR PLATINUM PROMISE

NICEIC registered contractors are required to ensure they have a robust complaints-handling process. If you have concerns about any non-compliant works completed by a contractor who is registered with NICEIC, the first step is to make contact with the contractor. You should raise your concerns and allow a reasonable amount of time for them to be resolved.

If that doesn't resolve the situation, NICEIC may be able to step in to investigate. If you believe your contractor has delivered work with clear deviations from industry standards, we'll discuss the technical nature of your complaint with our registered contractor. We aim to mediate between all parties to reach a resolution.

Should the contractor cease to trade then please contact us and we will guide you through the NICEIC Platinum promise and how we can help.

Further details including full conditions and exclusions can be found at -

www.niceic.com/householder/platinumpromise



This certificate is not valid if the serial number has been defaced or altered

29067751

MWC18.2c

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE

Issued in accordance with BS 7671: 2018+A2:2022 - Requirements for Electrical Installations
To be used only for minor work that does not include the provision of a new circuit

PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR	(*Where applicable)	DETAILS OF THE CLIENT	DETAILS OF THE INSTALLATION
Registration No: 025998000	Branch No*: 000	Contractor Reference Number (CRN): N/A	Occupier: Lynda Mumford
Trading Title: Yardley Electrical Services		Name: Lynda Mumford	UPRN: N/A
Address: Oak Lodge, Woodside Hamlet, Ham Manor Park, Llantwit Major, South Glamorgan		Address: c/o St Giles Church, Gileston, Barry	Address: c/o St Giles Church, Gileston, Barry
Postcode: CF61 1BN	Tel No: 07702386567	Postcode: CF62 4HX	Tel No: N/A

PART 2 : DETAILS OF THE MINOR WORKS, SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Description of Minor Works: Additional outside lights via underground supply

Date completed: 13/03/2024 System type and earthing arrangements (e.g. TN-C-S / TN-S / TT): TN-C-S Z_s at Distribution Board / Consumer Unit supplying the final circuit: (0.22) Ω

Presence of adequate main protective conductors Earthing conductor: (✓) Protective bonding conductor(s) to: Water (N/A) Gas (N/A) Oil (N/A) Other (state) N/A

Comments on existing installation (see Reg. 644.1.2): N/A Page No: (N/A)

Details of any departures from BS 7671: 2018, as amended to (date) for the circuit altered or extended (Regulation 120.3, 133.1.3 & 133.5): N/A

Details of permitted exceptions (Regulation 411.3.3): N/A Where applicable, risk assessment attached: (N/A)

PART 3 : CIRCUIT DETAILS

DB/Consumer Unit: Ref No DB1 Location and type Church cupboard

Circuit Description and Ref No: 2. Outside and porch lights Installation reference method: D Number of conductors: (2) Csa of conductors Live: (1.5) mm² cpc: (1.5) mm²

Overcurrent protection device BS EN: 61009 Type: B Rating: 6 (A) RCD BS EN: 61009 Type: AC Rating: 6 (A) AFDD BS EN: N/A Type: N/A Rating: (A) SPD BS EN: N/A Type: N/A

Rated residual operating current ($I_{\Delta n}$): (30) mA

PART 4 : TEST RESULTS FOR THE CIRCUIT ALTERED OR EXTENDED**

Continuity	Protective conductor ($R_1 + R_2$): (1.21) Ω	or	R_2 : (N/A) Ω
Ring final circuit (loop values)	L/L: (N/A) Ω	N/N: (N/A) Ω	cpc/cpc: (N/A) Ω
Insulation Resistance***	L/L: (200) M Ω	L/E: (7.38) M Ω	Test voltage: (250) V
*** Where an agreed limitation is used provide details on a separate page and append to the certificate.			
Polarity	Satisfactory: (✓)	Maximum measured earth fault loop impedance Z_s	(1.43) Ω
Circuit protective devices functionality checks			
RCD test button operation satisfactory:	(✓)	AFDD test button operation satisfactory (where provided):	N/A
RCD disconnection time at $I_{\Delta n}$:	(18.7) ms	SPD functionality confirmed (where indicator is provided):	N/A
Test Instrument	Multifunction: (21200216)	Other(s) (state):	N/A
(insert serial numbers)	(N/A)	(N/A)	(N/A)

PART 5 : DECLARATION

I CERTIFY that the work covered by this certificate does not impair the safety of the existing installation and that the work has been designed, constructed, inspected and tested in accordance with BS 7671: 2018, amended to 2022 (date) and that to the best of my knowledge and belief, at the time of my inspection, complied with BS 7671: 2018+A2:2022 except as detailed in PART 2 of this certificate.

Name (capitals): BEN DINEEN

Signature: [Signature] for and on behalf of the Contractor identified in PART 1 of this Certificate

Position: Electrician Date: 13/03/2024

The results of the inspection and testing reviewed by the Qualified Supervisor

Name (capitals): TERRY SEDGEBEER

Signature: [Signature] Date: 13/03/2024

**where relevant and practicable

Original (to the person ordering the work)

NOTES FOR RECIPIENT

THIS SAFETY CERTIFICATE IS AN IMPORTANT AND VALUABLE DOCUMENT, WHICH SHOULD BE RETAINED FOR FUTURE REFERENCE

This safety certificate has been issued to confirm that the minor electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with the national standard for the safety of electrical installations, *BS 7671: 2018+A2:2022* - Requirements for Electrical Installations.

You should have received the certificate marked 'Original' and the contractor should retain a duplicate. If you were the person ordering the work, but not the owner or user of the installation, you should pass this certificate, or a full copy of it, immediately to the owner or user of the installation.

The 'Original' certificate should be retained in a safe place and shown to any person inspecting, or undertaking further work on the electrical installation in the future. If you later vacate the property, this certificate will demonstrate to the new user that the minor electrical installation works complied with the requirements of *BS 7671: 2018+A2:2022* at the time the certificate was issued.

For safety reasons, the complete electrical installation, including the minor electrical installation works that is the subject of this certificate, will need to be inspected and tested at appropriate intervals by a skilled person or persons, competent in such work.

Only the contractor as identified and recorded in PART 1 of this certificate, being responsible for the electrical work documented, is authorised to issue this NICEIC certificate. The certificate has a printed seven digit serial number that is traceable to the contractor to which it was supplied by NICEIC.

The Minor Electrical Installation Works Certificate is intended to be used only for an addition or alteration to an existing circuit that does not extend to the provision of a new circuit. Examples include the addition of a socket-outlet or a lighting point to an existing circuit, or the replacement or relocation of a light switch. This certificate may also be used for the replacement of equipment such as accessories or luminaires, but not for the replacement of distribution boards, consumer units or similar items. This certificate would be considered by NICEIC to be invalid if you requested the contractor to undertake more extensive work, for which an Electrical Installation Certificate should have been issued. A separate certificate should have been received for each existing circuit on which minor works have been carried out.

Where the installation incorporates a residual current device (RCD) it should be tested every six months. **For safety reasons it is important that this instruction is followed.**

The test is a functional test involving the pressing of a button marked 'T' or 'Test'. The device should switch off the supply and once reset, restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility, it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions should be followed with respect to test button operation.

Where the installation includes a surge protection device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice.

PART 4 of the certificate is intended to facilitate the recording of information associated with the testing of the modified circuit, and the related parts of the existing installation on which the modified circuit depends for its safety. Generally, each field should have been completed to confirm the results of a particular test by insertion of a measured value or a '✓'. Where a particular test was not relevant this should have been indicated by 'N/A', meaning 'Not Applicable'.

Additionally and where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

Should the person ordering the work (e.g. the client, as identified on this certificate), have reason to believe that any element of the work for which the contractor has accepted responsibility (as indicated by the signature on this certificate) does not comply with the requirements of *BS 7671: 2018+A2:2022*, the client should in the first instance raise the specific concerns in writing with the contractor. If the concerns remain unresolved, the client may make a formal complaint to NICEIC, for which purpose a standard complaint form is available on request, as well as via the NICEIC website.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

For further information about electrical safety and how NICEIC can help you, visit:

www.niceic.com

NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).



This certificate is not valid if the serial number has been defaced or altered

29067766

MWC18.2c

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE

Issued in accordance with BS 7671: 2018+A2:2022 - Requirements for Electrical Installations
To be used only for minor work that does not include the provision of a new circuit

PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR (*Where applicable)		DETAILS OF THE CLIENT	DETAILS OF THE INSTALLATION	
Registration No: 025998000	Branch No*: 000	Contractor Reference Number (CRN): N/A	Occupier: Lynda Mumford	
Trading Title: Yardley Electrical Services		Name: Lynda Mumford	UPRN: N/A	
Address: Oak Lodge, Woodside Hamlet, Ham Manor Park, Llantwit Major, South Glamorgan		Address: c/o St Giles Church, Gileston, Barry	Address: c/o St Giles Church, Gileston, Barry	
Postcode: CF61 1BN	Tel No: 07702386567	Postcode: CF62 4HX	Tel No: N/A	

PART 2 : DETAILS OF THE MINOR WORKS, SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Description of Minor Works: Replace/reposition existing lights x10; 2x additional lights to altar area

Date completed: 13/03/2024 System type and earthing arrangements (e.g. TN-C-S / TN-S / TT): TN-C-S Z_s at Distribution Board / Consumer Unit supplying the final circuit: (0.22) Ω

Presence of adequate main protective conductors Earthing conductor: (✓) Protective bonding conductor(s) to: Water (N/A) Gas (N/A) Oil (N/A) Other (state) N/A

Comments on existing installation (see Reg. 644.1.2): N/A Page No: (N/A)

Details of any departures from BS 7671: 2018, as amended to (date) for the circuit altered or extended (Regulation 120.3, 133.1.3 & 133.5): N/A

Details of permitted exceptions (Regulation 411.3.3): N/A Where applicable, risk assessment attached: (N/A)

PART 3 : CIRCUIT DETAILS

DB/Consumer Unit: Ref No DB1 Location and type Church cupboard

Circuit Description and Ref No: 1. Lights Installation reference method: C Number of conductors: (2) Csa of conductors Live: (1.5) mm² cpc: (1.5) mm²

Overcurrent protection device	RCD	BS EN: 61009	Type: AC	Rating: 10 (A)	AFDD	BS EN: N/A	Type: N/A	Rating: (A)
BS EN: 61009	Type: B	Rated residual operating current ($I_{\Delta n}$): (30) mA			SPD	BS EN: N/A	Type: N/A	

PART 4 : TEST RESULTS FOR THE CIRCUIT ALTERED OR EXTENDED**

Continuity	Protective conductor ($R_1 + R_2$): (0.77) Ω	or	R_2 : (N/A) Ω
Ring final circuit (loop values)	L/L: (N/A) Ω	N/N: (N/A) Ω	cpc/cpc: (N/A) Ω
Insulation Resistance***	L/L: (41.8) M Ω	L/E: (.36.8) M Ω	Test voltage: (250) V
*** Where an agreed limitation is used provide details on a separate page and append to the certificate.			
Polarity	Satisfactory: (✓)	Maximum measured earth fault loop impedance Z_s	(0.99) Ω
Circuit protective devices functionality checks			
RCD test button operation satisfactory: (✓)	AFDD test button operation satisfactory (where provided): N/A		
RCD disconnection time at $I_{\Delta n}$: (.18.9) ms	SPD functionality confirmed (where indicator is provided): N/A		
Test Instrument	Multifunction: (21200216)	Other(s) (state): N/A	(N/A)

PART 5 : DECLARATION

I CERTIFY that the work covered by this certificate does not impair the safety of the existing installation and that the work has been designed, constructed, inspected and tested in accordance with BS 7671: 2018, amended to 2022 (date) and that to the best of my knowledge and belief, at the time of my inspection, complied with BS 7671: 2018+A2:2022 except as detailed in PART 2 of this certificate.

Name (capitals): BEN DINEEN

Signature: for and on behalf of the Contractor identified in PART 1 of this Certificate

Position: Electrician Date: 13/03/2024

The results of the inspection and testing reviewed by the Qualified Supervisor

Name (capitals): TERRY SEDGEBEER

Signature: Date: 13/03/2024

**where relevant and practicable

Original (to the person ordering the work)

NOTES FOR RECIPIENT

THIS SAFETY CERTIFICATE IS AN IMPORTANT AND VALUABLE DOCUMENT, WHICH SHOULD BE RETAINED FOR FUTURE REFERENCE

This safety certificate has been issued to confirm that the minor electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with the national standard for the safety of electrical installations, *BS 7671: 2018+A2:2022* - Requirements for Electrical Installations.

You should have received the certificate marked 'Original' and the contractor should retain a duplicate. If you were the person ordering the work, but not the owner or user of the installation, you should pass this certificate, or a full copy of it, immediately to the owner or user of the installation.

The 'Original' certificate should be retained in a safe place and shown to any person inspecting, or undertaking further work on the electrical installation in the future. If you later vacate the property, this certificate will demonstrate to the new user that the minor electrical installation works complied with the requirements of *BS 7671: 2018+A2:2022* at the time the certificate was issued.

For safety reasons, the complete electrical installation, including the minor electrical installation works that is the subject of this certificate, will need to be inspected and tested at appropriate intervals by a skilled person or persons, competent in such work.

Only the contractor as identified and recorded in PART 1 of this certificate, being responsible for the electrical work documented, is authorised to issue this NICEIC certificate. The certificate has a printed seven digit serial number that is traceable to the contractor to which it was supplied by NICEIC.

The Minor Electrical Installation Works Certificate is intended to be used only for an addition or alteration to an existing circuit that does not extend to the provision of a new circuit. Examples include the addition of a socket-outlet or a lighting point to an existing circuit, or the replacement or relocation of a light switch. This certificate may also be used for the replacement of equipment such as accessories or luminaires, but not for the replacement of distribution boards, consumer units or similar items. This certificate would be considered by NICEIC to be invalid if you requested the contractor to undertake more extensive work, for which an Electrical Installation Certificate should have been issued. A separate certificate should have been received for each existing circuit on which minor works have been carried out.

Where the installation incorporates a residual current device (RCD) it should be tested every six months. **For safety reasons it is important that this instruction is followed.**

The test is a functional test involving the pressing of a button marked 'T' or 'Test'. The device should switch off the supply and once reset, restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility, it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions should be followed with respect to test button operation.

Where the installation includes a surge protection device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice.

PART 4 of the certificate is intended to facilitate the recording of information associated with the testing of the modified circuit, and the related parts of the existing installation on which the modified circuit depends for its safety. Generally, each field should have been completed to confirm the results of a particular test by insertion of a measured value or a '✓'. Where a particular test was not relevant this should have been indicated by 'N/A', meaning 'Not Applicable'.

Additionally and where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

Should the person ordering the work (e.g. the client, as identified on this certificate), have reason to believe that any element of the work for which the contractor has accepted responsibility (as indicated by the signature on this certificate) does not comply with the requirements of *BS 7671: 2018+A2:2022*, the client should in the first instance raise the specific concerns in writing with the contractor. If the concerns remain unresolved, the client may make a formal complaint to NICEIC, for which purpose a standard complaint form is available on request, as well as via the NICEIC website.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

For further information about electrical safety and how NICEIC can help you, visit:

www.niceic.com

NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).



This certificate is not valid if the serial number has been defaced or altered

29067772

MWC18.2c

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE

Issued in accordance with BS 7671: 2018+A2:2022 - Requirements for Electrical Installations
To be used only for minor work that does not include the provision of a new circuit

PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR (*Where applicable)		DETAILS OF THE CLIENT	DETAILS OF THE INSTALLATION	
Registration No: 025998000	Branch No*: 000	Contractor Reference Number (CRN): N/A	Occupier: Lynda Mumford	
Trading Title: Yardley Electrical Services		Name: Lynda Mumford	UPRN: N/A	
Address: Oak Lodge, Woodside Hamlet, Ham Manor Park, Llantwit Major, South Glamorgan		Address: c/o St Giles Church, Gileston, Barry	Address: c/o St Giles Church, Gileston, Barry	
Postcode: CF61 1BN	Tel No: 07702386567	Postcode: CF62 4HX	Tel No: N/A	Postcode: CF62 4HX
				Tel No: N/A

PART 2 : DETAILS OF THE MINOR WORKS, SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Description of Minor Works: Additional socket to altar area

Date completed: 13/03/2024 System type and earthing arrangements (e.g. TN-C-S / TN-S / TT): TN-C-S Z_s at Distribution Board / Consumer Unit supplying the final circuit: (0.22) Ω

Presence of adequate main protective conductors Earthing conductor: (✓) Protective bonding conductor(s) to: Water (N/A) Gas (N/A) Oil (N/A) Other (state) N/A

Comments on existing installation (see Reg. 644.1.2): N/A Page No: (N/A)

Details of any departures from BS 7671: 2018, as amended to (date) for the circuit altered or extended (Regulation 120.3, 133.1.3 & 133.5): N/A

Details of permitted exceptions (Regulation 411.3.3): N/A Where applicable, risk assessment attached: (N/A)

PART 3 : CIRCUIT DETAILS

DB/Consumer Unit: Ref No DB1 Location and type Church cupboard

Circuit Description and Ref No: 6. Heater & Socket Installation reference method: C Number of conductors: (2) Csa of conductors Live: (1.5) mm² cpc: (1.5) mm²

Overcurrent protection device	RCD	BS EN: 61008	Type: AC	Rating: 80 (A)	AFDD	BS EN: N/A	Type: N/A	Rating: (A)
BS EN: 60898	Type: B	Rated residual operating current ($I_{\Delta n}$): (30) mA			SPD	BS EN: N/A	Type: N/A	

PART 4 : TEST RESULTS FOR THE CIRCUIT ALTERED OR EXTENDED**

Continuity	Protective conductor ($R_1 + R_2$): (0.61) Ω	or	R_2 : (N/A) Ω
Ring final circuit (loop values)	L/L: (N/A) Ω	N/N: (N/A) Ω	cpc/cpc: (N/A) Ω
Insulation Resistance***	L/L: (111.9) M Ω	L/E: (99.8) M Ω	Test voltage: (500) V
*** Where an agreed limitation is used provide details on a separate page and append to the certificate.			
Polarity	Satisfactory: (✓)	Maximum measured earth fault loop impedance Z_s	(0.64) Ω
Circuit protective devices functionality checks			
RCD test button operation satisfactory:	(✓)	AFDD test button operation satisfactory (where provided):	N/A
RCD disconnection time at $I_{\Delta n}$:	(9.8) ms	SPD functionality confirmed (where indicator is provided):	N/A
Test Instrument	Multifunction: (21200216)	Other(s) (state):	N/A
(insert serial numbers)	(N/A)	(N/A)	(N/A)

PART 5 : DECLARATION

I CERTIFY that the work covered by this certificate does not impair the safety of the existing installation and that the work has been designed, constructed, inspected and tested in accordance with BS 7671: 2018, amended to 2022 (date) and that to the best of my knowledge and belief, at the time of my inspection, complied with BS 7671: 2018+A2:2022 except as detailed in PART 2 of this certificate.

Name (capitals): BEN DINEEN

Signature: for and on behalf of the Contractor identified in PART 1 of this Certificate

Position: Electrician Date: 13/03/2024

The results of the inspection and testing reviewed by the Qualified Supervisor

Name (capitals): TERRY SEDGEBEER

Signature: Date: 13/03/2024

**where relevant and practicable

Original (to the person ordering the work)

NOTES FOR RECIPIENT

THIS SAFETY CERTIFICATE IS AN IMPORTANT AND VALUABLE DOCUMENT, WHICH SHOULD BE RETAINED FOR FUTURE REFERENCE

This safety certificate has been issued to confirm that the minor electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with the national standard for the safety of electrical installations, *BS 7671: 2018+A2:2022* - Requirements for Electrical Installations.

You should have received the certificate marked 'Original' and the contractor should retain a duplicate. If you were the person ordering the work, but not the owner or user of the installation, you should pass this certificate, or a full copy of it, immediately to the owner or user of the installation.

The 'Original' certificate should be retained in a safe place and shown to any person inspecting, or undertaking further work on the electrical installation in the future. If you later vacate the property, this certificate will demonstrate to the new user that the minor electrical installation works complied with the requirements of *BS 7671: 2018+A2:2022* at the time the certificate was issued.

For safety reasons, the complete electrical installation, including the minor electrical installation works that is the subject of this certificate, will need to be inspected and tested at appropriate intervals by a skilled person or persons, competent in such work.

Only the contractor as identified and recorded in PART 1 of this certificate, being responsible for the electrical work documented, is authorised to issue this NICEIC certificate. The certificate has a printed seven digit serial number that is traceable to the contractor to which it was supplied by NICEIC.

The Minor Electrical Installation Works Certificate is intended to be used only for an addition or alteration to an existing circuit that does not extend to the provision of a new circuit. Examples include the addition of a socket-outlet or a lighting point to an existing circuit, or the replacement or relocation of a light switch. This certificate may also be used for the replacement of equipment such as accessories or luminaires, but not for the replacement of distribution boards, consumer units or similar items. This certificate would be considered by NICEIC to be invalid if you requested the contractor to undertake more extensive work, for which an Electrical Installation Certificate should have been issued. A separate certificate should have been received for each existing circuit on which minor works have been carried out.

Where the installation incorporates a residual current device (RCD) it should be tested every six months. **For safety reasons it is important that this instruction is followed.**

The test is a functional test involving the pressing of a button marked 'T' or 'Test'. The device should switch off the supply and once reset, restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility, it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions should be followed with respect to test button operation.

Where the installation includes a surge protection device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice.

PART 4 of the certificate is intended to facilitate the recording of information associated with the testing of the modified circuit, and the related parts of the existing installation on which the modified circuit depends for its safety. Generally, each field should have been completed to confirm the results of a particular test by insertion of a measured value or a '✓'. Where a particular test was not relevant this should have been indicated by 'N/A', meaning 'Not Applicable'.

Additionally and where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

Should the person ordering the work (e.g. the client, as identified on this certificate), have reason to believe that any element of the work for which the contractor has accepted responsibility (as indicated by the signature on this certificate) does not comply with the requirements of *BS 7671: 2018+A2:2022*, the client should in the first instance raise the specific concerns in writing with the contractor. If the concerns remain unresolved, the client may make a formal complaint to NICEIC, for which purpose a standard complaint form is available on request, as well as via the NICEIC website.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

For further information about electrical safety and how NICEIC can help you, visit:

www.niceic.com

NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).